

**NEW HAMPSHIRE STATE BUILDING CODE  
PROPOSED AMENDMENT FORM**

---

Proposed amendment submitted by:

Name: Michael Hagan

Date: Aug 28, 2019

Company /Organization: NHBOA

Address: 25 Triangle Park Dr., Concord, NH 03301

Telephone: 603-352-5440

E-mail: mhagan@ci.keene.nh.us

---

Applicable code: ANSI A117.12009

Applicable code section: 603.5.1

Select only one code: IEBC-15 **IBC-15** IRC-15 IPC-15 IMC-15 IECC-15 IEBC-15 NEC-17 (NFPA 70)

**ANSI A117.1-2009**

Current language (including section numbers and include prior adopted amendments):

**Current language does not exist**

Check one: ☐ Delete without substitution: ☒ Add new section to read as follows:

☐ Delete section and substitute the following: ☐ Revise section to read as follows:

~~Show Line through material to be deleted.~~

Underline material to be added.

Proposed code language:

**603.7 Universal Changing Station.** Universal Changing Station shall be *powered height adjustable, be able to lower to a height of no less than 8 inches and raise to height of no less than 34 inches, be at least 25 inches wide by 72 inches in length, and support up to at least 330 pounds.*

Reason / Justification:

This is offered in response to recent legislation HB 628. Given the size thresholds, the family or assisted use toilet room would be required anyway, so the only added cost is the changing table itself.

Financial Analysis/Fiscal Impact of proposed amendment:

This will add \$2,000 to \$5,000 to the cost of construction.

---

For Building Code Review Board Use:

Not approved: \_\_\_\_\_

Approved: \_\_\_\_\_

Approved with modifications: \_\_\_\_\_

Scheduled Hearing Date: \_\_\_\_\_

Exhibit #: \_\_\_\_\_

Chair's Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Printed Name: \_\_\_\_\_